

DECLARATION OF PERFORMANCE No. PM/CFDM-V/01/25/1

1.	Unique identification code of the product-type	CFDM		
2.	Products	Dampers – Fire dampers		
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.		
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 118/16		
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz, www.mandik.com		
5.	System of AVCP	System 1		
6.	Harmonised standard	EN 15650:2010		
	Notified body	Notified body No. 1391		
		PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek		
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2020/0129/O1 Assessment Report of Performance of Construction Product No. P-1391-CPR-2020/0129		

· · · · · · · · · · · · · · · · · · ·	fire resistance classification accordance with EN 15650:2010, art. 4.1.1	
Fire separating construction, location of the damper	Installation type, installation system	Performance – class of fire resistance
Solid wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ^{1]} Mineral wool with fire protection coating and cement lime plate ^{1]}	As per purchase order EI 120 ($v_e i \leftrightarrow o$) S, or EI 90 ($v_e i \leftrightarrow o$) S, or EI 60 ($v_e i \leftrightarrow o$) S.
	Ablative Coated Batt 1]	As per purchase order EI 90 ($v_e \mapsto 0$) S, or EI 60 ($v_e \mapsto 0$) S.
Gypsum plasterboard wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ^{1]} Mineral wool with fire protection coating and cement lime plate ^{1]}	As per purchase order EI 120 ($v_e i\leftrightarrow o$) S, or EI 90 ($v_e i\leftrightarrow o$) S, or EI 60 ($v_e i\leftrightarrow o$) S.
	Ablative Coated Batt 1]	As per purchase order EI 90 ($v_e \mapsto 0$) S, or EI 60 ($v_e \mapsto 0$) S.
Solid ceiling construction – damper in the ceiling – 150 mm min ceiling thickness	Mortar or gypsum 1] Ablative Coated Batt 1]	As per fire resistance class shown on the purchase order EI 90 ($h_o \mapsto 0$) S, or EI 60 ($h_o \mapsto 0$) S.

^{1]} Refer to <u>Technical documentation</u> for the details of the installation type / installation system.

7b.	Declared performances – essential characteristics				
Essential characteristics		Requirements (provisions of the harmonised standard EN 15650:2010)	Performance (lever or class) / Compliance with the requirements		
Nom	inal activation conditions/sensitivity:	4.2.1.2	Conforms		
 sensing element load bearing capacity 		4.2.1.2.2	Conforms		
– sei	nsing element response temperature	4.2.1.2.3	Conforms		
	oonse delay (response time): sure time	4.2.1.3	Conforms		
Oper	rational reliability: cling	4.3.1, a)	0 cycles – conforms		
– sei	bility of response delay: nsing element response to temperature load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms		
Dura	bility of operational reliability: ening and closing cycle tests	4.3.3.2	NPD – no performance determined		

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02

Mgr. Jan Mičan CEO, ppa MANDÍK, a.s.

Characteristics	Technical standard	Performance (lever or class) / Compliance with the requirements
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms
Application with no duct connected	EN 1366-2:2018, 6.2.7	Conforms