

DECLARATION OF PERFORMANCE No. PM/FDMQ/01/25/1

1.	Unique identification code of	FDMQ	
	the product-type		
2.	Products	Fire dampers	
	Intended use	To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.	
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 103/14	
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz, www.mandik.com	
5.	System of AVCP	System 1	
6.	Harmonised standard	EN 15650:2010	
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek	
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2024/0009 Assessment Report of Performance of Construction Product No. P-1391-CPR-2024/0009	

7a. Declared performances – fire	resistance classification			
· · · · · · · · · · · · · · · · · · ·	Essential characteristics in accordance with EN 15650:2010, art. 4.1.1			
Fire separating construction,	Installation type, installation system	Performance		
location of the damper		 class of fire resistance 		
Solid wall construction	Mortar or gypsum 1]			
 damper in the wall 	Battery – mortar or gypsum 1]]		
 100 mm min. wall thickness 	Installation next to the wall – mortar or			
	gypsum + mineral wool 1]			
	Mineral wool with fire-resistant coating and	El 90 (v _e i↔o) S		
	calcium silicate boards 1]			
	Installation frame E1, E2, E4 1]			
	Ablative coated batt 1]			
Solid wall construction	Insulation of the duct with calcium silicate			
 damper remote from the wall 	boards – installation frame E6 1]			
 100 mm min. wall thickness 	Insulation of the duct with mineral wool	El 90 (v _e i↔o) S		
	- mineral wool with fire-resistant coating			
	and calcium silicate boards 1]			
	Insulation of the duct with mineral wool			
	- mortar or gypsum 1]	El 60 (v _e i↔o) S		
	Insulation of the duct with mineral wool	L1 00 (V _e K-70) 0		
	Ablative coated batt 1]			

(table continues)

1] Refer to $\underline{\text{Technical documentation}}$ for the details of the installation type / installation system.

(continuation of the table)

(continuation of the table)		
Fire separating construction,	Installation type, installation system	Performance
location of the damper		 class of fire resistance
Gypsum plasterboard	Mortar or gypsum 1]	
wall construction	Battery – mortar or gypsum 1]	
 damper in the wall 	Installation next to the wall – mortar or	
 100 mm min. wall thickness 	gypsum + mineral wool 1]	
	Mineral wool with fire-resistant coating and	El 90 (v _e i↔o) S
	calcium silicate boards 1]	
	Installation frame E1, E3 1]	
	Ablative coated batt 1]	
	Flexible ceiling – installation frame E5 1]	
Gypsum plasterboard	Insulation of the duct with mineral wool	
wall construction	- Mineral wool with fire-resistant coating	El 90 (v _e i↔o) S
 damper remote from the wall 	and calcium silicate boards 1]	
 100 mm min. wall thickness 	Insulation of the duct with mineral wool	
	- mortar or gypsum 1]	FI 60 (v. i.v.s) 6
	Insulation of the duct with mineral wool	El 60 (v _e i↔o) S
	Ablative coated batt 1]	
Sandwich wall construction	Ruukki SPB W – Weichschott/Ablative	
 damper in the wall 	coated batt and calcium silicate boards 1]	51.00 (;) 0
 100 mm min. wall thickness 	Paroc AST S – Weichschott/Ablative	El 90 (v _e i↔o) S
	coated batt and calcium silicate boards 1]	
Solid ceiling construction	Mortar or gypsum 1]	
- damper in the ceiling	Battery – mortar or gypsum 1]	1
- 150 mm min. ceiling thickness	Mineral wool with fire-resistant coating and	El 90 (h₀ i↔o) S
	calcium silicate boards 1]	Li 30 (ii ₀ k 70) 0
	Installation frame E1, E2, E4 1]	1
	Ablative coated batt 1]	1
Solid ceiling construction	Insulation of the duct with mineral wool	
damper remote from the ceiling	+ mortar or gypsum 1]	
- 150 mm min. ceiling thickness	Concrete 1]	1
	Concrete with installation frame E4 1]	El 90 (h₀ i↔o) S
	Insulation of the duct with calcium silicate	1
	boards – installation frame E6 1]	
Thin shaft construction 1]	Mortar or gypsum 1]	F1 00 (; ,) 0
	Installation frame E1 1]	El 90 (v _e i↔o) S
		L

^{1]} Refer to $\underline{\text{Technical documentation}}$ for the details of the installation type / installation system.

7b.	Declared performances – essential characteristics				
	Essential characteristics in accordance with EN 15650:2010, art. 4.1.1				
Essential characteristics		Requirements (provisions of the harmonised standard EN 15650:2010)	Performance (lever or class) / Compliance with the requirements		
Nominal activation conditions/sensitivity:		4.2.1.2	Conforms		
- sensing element load bearing capacity		4.2.1.2.2	Conforms		
 sensing element response temperature 		4.2.1.2.3	Conforms		
Response delay (response time): – closure time		4.2.1.3	Conforms		
Oper	ational reliability: cling	4.3.1, a)	50 cycles – conforms		
- ser	bility of response delay: nsing element response to erature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms		
	bility of operational reliability: ening and closing cycle tests	4.3.3.2	Dampers with control mechanisms - manual Mandík M: NPD - Mandík MODULAR: C ₃₀₀ - Belimo, Schischek: C _{10.000} - Gruner: C _{MOD}		

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02

..

Jan Mičan CEO, Ppa MANDÍK, a.s.

Declared performances – other characteristics						
Characteristics	Technical standard	Performance (level or class) / Compliance with the requirements				
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms				
Application with no ducting	EN 1366-2:2015 art. 6.2.7	Conforms				
Damper blade tightness	EN 1751:2024	Class 3				
Damper casing tightness	EN 1751:2024	Class ATC 3 (old marking "C")				

Additional provisions for use of the product in Austria

The product-type products meet also all requirements of ÖNORM H 6025 standard, cf. Assessment Report of Performance of Construction Product No. P-1391-CPR-2024/0009.