

1.	Unique identification code of the product-type	<b>FDMQ 120</b>
2.	Products	Fire dampers
	Intended use	To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications 162/22
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 <a href="mailto:mandik@mandik.cz">mandik@mandik.cz</a> , <a href="http://www.mandik.com">www.mandik.com</a>
5.	System of AVCP	System 1
6.	Harmonised standard	EN 15650:2010
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2025/0048 Assessment Report of Performance of Construction Product No. P-1391-CPR-2025/0048

7a.	<b>Declared performances – fire resistance classification</b> Essential characteristics in accordance with EN 15650:2010, art. 4.1.1	
<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance <sup>2)</sup></i>
Solid wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H] <sup>3)</sup>
	Battery – mortar or gypsum <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H]
	Ablative Coated Batt <sup>1)</sup>	
Solid wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with mineral wool + ablative coated batt – ISOVER ULTIMATE PROTECT <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H]
	Flamebar EN Fire Duct – FPL 110 insulation <sup>1)</sup>	
Gypsum plasterboard wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H] <sup>3)</sup>
	Battery – mortar or gypsum <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H]
	Ablative Coated Batt <sup>1)</sup>	
Gypsum plasterboard wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with mineral wool + ablative coated batt – ISOVER ULTIMATE PROTECT <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H]
	Flamebar EN Fire Duct – FPL 110 insulation <sup>1)</sup>	

(table continues)

<sup>1)</sup> Refer to [Technical documentation](#) for the details of the installation type / installation system.

<sup>2)</sup> Fire resistance class markings in accordance with Commission Regulation (EU) 2024/1681.

<sup>3)</sup> Tested at increased underpressure of 500 Pa.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance <sup>2)</sup></i>
Sandwich wall construction Euroclad Firemaster Extra – damper in the wall – wall thickness min. 150 mm	Mineral wool with boards <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H]
Shaftwall construction – damper in the wall – wall thickness min. 105 mm	Mortar or gypsum <sup>1)</sup>	EI 120 (v <sub>e</sub> ) S [H]
	2 dampers in one installation opening – mortar or gypsum <sup>1)</sup>	
	2 dampers in one installation opening – ablative coated batt <sup>1)</sup>	
Solid ceiling construction – damper in the ceiling – 150 mm min. ceiling thickn.	Mortar or gypsum <sup>1)</sup>	EI 120 (h <sub>o</sub> ) S [H] <sup>3)</sup>
	Battery – mortar or gypsum <sup>1)</sup>	EI 120 (h <sub>o</sub> ) S [H]

<sup>1)</sup> Refer to [Technical documentation](#) for the details of the installation type / installation system.

<sup>2)</sup> Fire resistance class markings in accordance with Commission Regulation (EU) 2024/1681.


<sup>3)</sup> Tested at increased underpressure of 500 Pa.

7b.	<b>Declared performances – essential characteristics</b> Essential characteristics in accordance with EN 15650:2010, art. 4.1.1		
<i>Essential characteristics</i>	<i>Requirements (provisions of the harmonised standard EN 15650:2010)</i>	<i>Performance (lever or class) / Compliance with the requirements</i>	
Nominal activation conditions/sensitivity:	4.2.1.2	Conforms	
– sensing element load bearing capacity	4.2.1.2.2	Conforms	
– sensing element response temperature	4.2.1.2.3	Conforms	
Response delay (response time): – closure time	4.2.1.3	Conforms	
Operational reliability: – cycling	4.3.1, a)	50 cycles – conforms	
Durability of response delay: – sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms	
Durability of operational reliability: – opening and closing cycle tests	4.3.3.2	Dampers with control mechanisms - manual Mandík M: NPD - Mandík MODULAR: C <sub>300</sub> - Belimo: C <sub>10.000</sub>	

The performance of the product identified above is in conformity with the set of declared performance/s.  
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-05-06

  
Jan Mičan  
CEO, Ppa  
MANDÍK, a.s.

<b>Declared performances – other characteristics</b>		
<i>Characteristics</i>	<i>Technical standard</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms
Damper blade tightness	EN 1751:2024	Class 2
Damper casing tightness	EN 1751:2024	Class ATC 3 (old marking “C”)